

CASH ACME

A Division of the Reliance Worldwide Corporation

RE: Discharge (drain) line installation.

To whom it may concern:

Cash Acme recommends the following minimum requirement for the installation of Temperature and Pressure relief valves:

Discharge lines must be fitted to relief valves by means of threaded connection. Copper or type CPVC plastic tube will necessitate the use of thread x sweat (weld) transition fittings at this connection. Lines shall be as short as possible and be of the same size as the valve discharge connection (3/4", for example) throughout their entire length. Lines must pitch downward from the valves and terminate at least 6" above drains where discharge will be clearly visible. The discharge end of a line shall be plain (unthreaded). Discharge line material must suitable for at least 180F water, shall be no more than 30 feet in length or contain more than four elbows or bends. No valve of any type may be installed in the discharge lines.

John Brill
Cash Acme